

25X1A9a

REUR LETTER AND ENCLOSURES DATED THREE NOVEMBER SUBMITTING MECHANICAL SHOP DRAWINGS FOR CHECKING, ITEMS ONE TO FIVE INCLUSIVE. DRAWINGS APPROVED FOR GENERAL ARRANGEMENT SUBJECT TO CONTRACT REQUIREMENTS AND SPACE CONDITIONS FOR INSTALLATION. APPROVAL ALSO SUBJECT TO NOISE LIMITATIONS AS SPECIFIED AND MENTIONED IN LETTER TO YOU DATED 29 OCTOBER, SUBJECT: EQUIPMENT SUBMITTED FOR APPROVAL. COMPRESSOR SHOULD ALSO BE RELOCATED ACCORDING TO INSTRUCTION IN LETTER MENTIONED ABOVE.

Ø6/1745Z